

Test Verification of Conformity

Applicant : YUEQING SHUOPU ELECTRIC CO.,LTD
Address of Applicant : Sanli, Liushi Town, Yueqing, Zhejiang
Product Description : Distribution box (Junction box)
Ratings and principal characteristics : Ui:660V~ 50/60Hz IP40
Rated connecting capacity :
1.5 mm²~10 mm²

Model(s) : HC-TF series, HC-TS series

The sample(s) of the product have been tested for  marking and found to be in conformity with the requirements of the European Community Directive 2014/35/EU.

Test Standard : EN 60670-1:2005+A1:2013
EN 60670-22:2006

NOTE: The datas in the above form are only part of the full test report and it is invalid without the test report number: CNB3181128008-L-D

This verification has been granted to the applicant based on the result of the tests, performed by CTS Laboratory on the submitted samples of the above mentioned product in accordance with the provision of the relevant specific standards.

Copyright of this verification is owned by CTS Laboratory. This verification is subjected to the governance of the general conditions of services printed overleaf.

Signed for and on behalf of

CTS Laboratory (NINGBO)



Date: 30 November 2018